



ADDENDUM NO. 2

CITY OF DURHAM FLEET MAINTENANCE CENTER Roof and Envelope Renovations Durham, North Carolina

**PROJECT # 12-8196
April 18, 2013**

THIS ADDENDUM MODIFIES BIDDING AND CONTRACT DOCUMENTS FOR THE FLEET MAINTENANCE FACILITY, DATED APRIL 2, 2013 AND CONSISTS OF 1 PAGE, INCLUSIVE. CONTRACTOR SHALL INCORPORATE ALL CHANGES, REVISIONS, CORRECTIONS AND MODIFICATIONS INCLUDED IN THIS ADDENDUM INTO THE BID FOR THIS PROJECT. FAILURE OF THE CONTRACTOR TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM ON BID FORM MAY RESULT IN DISQUALIFICATION OF THE BID.

Item #1: Question:

Section 06100 2.1, B specifies for lumber to be fire retardant treated and pressure preservative treated. Lumber companies say that you can get either pressure treated or fire retardant treated lumber but that it is not available with both treatments. Please confirm what we should price in our bid.

*In our experience sometimes you can get both, but other times only one or the other, even at the same yard. We prefer both and specify as such but if not available, bidders are to bid **preservative treated lumber**.*

END OF ADDENDUM NO. 2